

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 55

Dated: 22.07.2026

It is certified that an inspection team headed by ARUN K. MEHTA (Name of Officers with designation) from PHED, LATEHAR (Name of Department/ Office) inspected GLITTER TRIVENI PUBLIC SCHOOL, CHANDWA, LATEHAR (Name & Address of the school) on 21/07/2026 (date of inspection), and on the basis of Water Test report (attached) bearing no. LTR-26.262 Dated: 21/07/2026 of District Level Water Testing Laboratory, LATEHAR (PHED LAB) certified that GLITTER TRIVENI PUBLIC SCHOOL has safe drinking water facilities for the students and member of staff of the institution. School is also maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/ U.T. Govt.

The certificate is valid till Six Month from date of Issue.

Signature with Seal: [Signature]

Name: ARUN K. MEHTA

Designation: Assistant Engineer

Assistant Engineer of
the Govt. Public Health Department
(PHED)/

Authorised officer of the Local Body
Name & Address of the Office /
Department: PHED, LATEHAR

To,

GLITTER TRIVENI PUBLIC SCHOOL
CHANDWA, LATEHAR, JHARKHAND

[Signature]
Principal
Glitter Triveni Public School
Chandwa Latehar- 829203

Kasambani Singh
MANAGER
Glitter Triveni Public School
Chandwa Latehar- 829203



TEST REPORT



TC-15324

Issued to : Glitter Triveni Public School, Lukuiya, Latehar, Jharkhand 829203.	ULR-TC153242600000262F Sample Code: - 260721RO-057A Date of Issue: -21.07.2026 Customer Reference No.- LTR-26-262
--	--

Sample Particulars					Sample Details	
Sample Name/Description: Drinking Water / Treated Water					Sample Received date: 21.07.2026	
Sample Quantity : 1 litre					Sample collected by: Customer	
Sample pkg. Condition : Good						
Group-Drinking water					Discipline: Chemical	
Test started on: - 21.07.2026			Test completed on :- 22.07.2026			
Sl. No.	Test Parameter	Unit	Results	Method	Specification as per APHA 24 th Edition 2023	
					Acceptable Limit	Permissible Limit (In Absence of Alternate source)
1	pH at 25 ^o C	-	7.01	APHA 24 th Ed.2023-4500-H ⁺ B, (Electrometric method)	6.5 – 8.5	No relaxation
2	Total Dissolved Solids at 180 ^o C	mg/L max	90	APHA 24 th Ed.2023-2540 C, (Total Dissolved Solids Dried at 180 ^o C)	500	2000
3	Turbidity	NTU max	0.01	APHA 24 th Ed.2023-2130 B, (Nephelometric method)	1	5
4	Colour	Hazen unit	5	APHA 24 th Ed.2023-2120 B, (Visual Comparison method)	5	15
5	Taste	-	Agreeable	IS 3025 (Part-7):2023 (Taste Threshold)	Agreeable	Agreeable
6	Odour	-	Agreeable	IS 3025 (Part-5)	Agreeable	Agreeable
7	Total Alkalinity as CaCO ₃	mg/L max	100	APHA 24 th Ed.2023-2320 B, (Titration method)	200	600
8	Total Hardness as CaCO ₃	mg/L max	220	APHA 24 th Ed.2023-2340 C, (EDTA Titration method)	200	600
9	Calcium as Ca	mg/L max	32.69	APHA 24 th Ed.2023-3500 Ca B, (EDTA Titration method)	75	200
10	Magnesium as Mg	mg/L max	16.27	APHA 24 th Ed.2023-3500-Mg B, (Calculation method)	30	100
11	Chloride as Cl	mg/L max	69.59	APHA 24 th Ed.2023-4500 Cl ⁻ B, (Argentometric method)	250	1000
12	Fluoride as F	mg/L max	0.04	APHA 24 th Ed.2023-4500 F ⁻ C, (Ion selective electrode method)	1.0	1.50

Remarks:-

Specific contractual notes: -

- The results listed refer only to the tested sample and applicable parameter.
- This report, in full or in part, shall not be used for advertising or as evidence in any court of law.
- This report can not be reproduced, except when in full, without the written permission of the Lab In-charge
- Tested Sample shall be retained up to Seven Days from the date of issue of the certificate.
- The liability of the laboratory is limited to the invoiced amount.

Principal

Glitter Triveni Public School
Chandwa Latehar- 829203

Kesamban Singh
MANAGER

Glitter Triveni Public School
Chandwa Latehar- 829203

-----End of the Report-----

Authorised Signatory